

# Baca 4 Flowtest

	SEP	TOTAL	STM						
DATE	TIME	HP	PRES	STEAM	WATER	MASS	FL	FRAC	ENTH
03/31/81	1000	58		59957	151863	221730	.27	(ASSUMED)	
03/31/81	1145	48		53799	145457	199256	.27	(ASSUMED)	
<del>03/31/81</del>	<del>1300</del>	<del>57</del>		<del>58052</del>	<del>150992</del>	<del>215954</del>	<del>.27</del>	<del>(ASSUMED)</del>	
03/31/81	1700	71		81453	220237	301696	.27	(ASSUMED)	
04/01/81	0615	64		77156	203608	285764	.27	(ASSUMED)	
<del>04/01/81</del>	<del>1115</del>	<del>132</del>	<del>125</del>	<del>57733</del>	<del>118371</del>	<del>176104</del>	<del>.323</del>	<del>607</del>	
04/01/81	1500	133	125	60505	118391	176396	.338	616	
04/02/81	0700	137	124.5	57733	104569	162302	.356	632	
<del>04/02/81</del>	<del>1215</del>	<del>132</del>	<del>125.5</del>	<del>50018</del>	<del>103193</del>	<del>154111</del>	<del>.371</del>	<del>645</del>	
04/03/81	0710	133	125.5	60019	94683	154707	.388	660	
04/04/81	1800	130	123.5	57425	91729	149154	.385	657	
<del>04/05/81</del>	<del>0920</del>	<del>131</del>	<del>124.5</del>	<del>62501</del>	<del>96173</del>	<del>158674</del>	<del>.394</del>	<del>655</del>	
04/06/81	0645	131	125	62390	93221	155611	.401	671	
04/06/81	1500	151	145.5	50092	94370	144462	.347	632	
<del>04/07/81</del>	<del>0645</del>	<del>151</del>	<del>147</del>	<del>51313</del>	<del>91185</del>	<del>142498</del>	<del>.360</del>	<del>644</del>	
04/07/81	1145	150	144	49359	92413	141772	.348	633	
04/08/81	0630	151	144	48179	91996	140175	.344	629	
<del>04/08/81</del>	<del>1335</del>	<del>151</del>	<del>145</del>	<del>49359</del>	<del>92398</del>	<del>141757</del>	<del>.348</del>	<del>633</del>	
04/09/81	0710	152	146	51076	92398	143474	.356	640	
04/10/81	1330	150	146.5	48328	95152	143306	.337	625	
<del>04/11/81</del>	<del>1020</del>	<del>150</del>	<del>144.5</del>	<del>49941</del>	<del>92011</del>	<del>141052</del>	<del>.352</del>	<del>636</del>	
04/12/81	1100	150	145	49378	94401	143779	.343	629	
04/13/81	0635	150	144.5	49359	92406	141765	.343	633	
<del>04/13/81</del>	<del>1300</del>	<del>150</del>	<del>145</del>	<del>48968</del>	<del>92413</del>	<del>139381</del>	<del>.337</del>	<del>623</del>	
04/14/81	0740	149	143	45441	93214	135655	.323	615	
04/15/81	0710	149	145	46996	92421	139317	.337	623	
<del>04/15/81</del>	<del>1130</del>	<del>151</del>	<del>146</del>	<del>48322</del>	<del>94367</del>	<del>142695</del>	<del>.339</del>	<del>625</del>	

Baca 4 Flowtest p. 2 of 5

04/16/81	1015	151	145.5	46968	93199	140166	.335	622
04/17/81	1050	149	144.5	44284	92621	136905	.324	612
04/18/81	1210	150	144	45531	91003	136554	.334	620
04/19/81	1115	149	143	44782	91215	135997	.329	616
04/20/81	0640	150	145	46597	91193	139990	.348	633
04/20/81	1400	150	144	45583	91621	137204	.332	619
04/21/81	0650	149	144	47955	90389	138344	.347	631
04/21/81	1135	151	146.5	47186	94362	141549	.333	621
04/22/81	0630	151	146	47186	91170	138356	.341	627
04/23/81	0655	152	146.5	48476	91155	139631	.347	633
04/24/81	0550	150	144.5	48179	90792	138971	.347	632
04/25/81	1205	150	145	43253	93997	142252	.339	625
04/26/81	0715	150	145.5	47186	94386	141572	.333	621
04/27/81	0730	150	145	48253	94394	142647	.338	624
04/28/81	0720	151	146	51234	97084	148318	.345	631
04/29/81	0700	149	144	46968	96348	143315	.330	615
04/30/81	0700	150	144.5	44422	96348	140770	.315	605
05/01/81	0640	148	143	46750	96355	143105	.327	614
05/02/81	1030	149	143	43724	97893	141617	.310	598
05/03/81	0900	148	143	44950	97513	142463	.315	604
05/04/81	0715	149	144	44377	96748	141125	.315	604
05/05/81	0700	151	145	43348	92412	141261	.346	631
05/06/81	0640	149	143	48030	97513	145543	.330	617
05/07/81	0640	150	145	47259	96348	143607	.329	617
05/08/81	0645	151	145	45795	96324	142119	.322	611
05/09/81	0845	149	143	44950	97140	142090	.315	605
05/10/81	0830	149	145	45020	97893	142913	.315	604
05/11/81	0750	150	145.5	45229	97861	143090	.316	605
05/11/81	1030	90	75	64956	91555	156511	.415	659
05/11/81	1325	83	75	60383	98355	158738	.380	628

Baca 4 Flowtest.

5	05/12/81	1115	87	75	59537	99531	159068	.374	622
6	05/13/81	1340	87	74.5	59537	97598	157135	.379	627
7	<del>05/14/81</del>	<del>0645</del>	<del>88</del>	<del>75</del>	<del>58913</del>	<del>97946</del>	<del>156259</del>	<del>.376</del>	<del>624</del>
8	05/15/81	0720	87	74.5	57374	96399	154273	.375	623
9	05/16/81	1155	85	75	53466	97186	150652	.355	605
10	<del>05/17/81</del>	<del>0800</del>	<del>87</del>	<del>75.5</del>	<del>52275</del>	<del>97186</del>	<del>149451</del>	<del>.350</del>	<del>601</del>
11	05/18/81	0800	87	74.5	53466	97186	150652	.355	605
12	05/19/81	1115	130	124	43819	99361	143180	.306	588
13	<del>05/20/81</del>	<del>1500</del>	<del>130</del>	<del>125</del>	<del>43974</del>	<del>99762</del>	<del>143676</del>	<del>.306</del>	<del>590</del>
14	05/21/81	1410	129	124	44386	99352	143738	.309	590
15	05/22/81	0730	130	124.5	44308	98958	143266	.309	591
16	<del>05/23/81</del>	<del>1515</del>	<del>130</del>	<del>125</del>	<del>44386</del>	<del>98967</del>	<del>143253</del>	<del>.310</del>	<del>591</del>
17	05/24/81	0915	132	127	44128	99327	143455	.308	591
18	05/25/81	0855	131	126	45106	100820	145226	.309	591
19	<del>05/26/81</del>	<del>0715</del>	<del>130</del>	<del>125</del>	<del>44386</del>	<del>98967</del>	<del>143353</del>	<del>.310</del>	<del>591</del>
20	05/27/81	0630	129	124	44737	99353	144140	.311	592
21	05/28/81	1300	130	125	44747	99711	144456	.310	592
22	<del>05/29/81</del>	<del>0725</del>	<del>133</del>	<del>129</del>	<del>45422</del>	<del>100785</del>	<del>146207</del>	<del>.311</del>	<del>594</del>
23	05/30/81	0700	131	126	44386	98580	142964	.311	593
24	05/31/81	0715	130	125	44386	98958	143344	.310	592
25	<del>06/01/81</del>	<del>0715</del>	<del>132</del>	<del>126</del>	<del>43036</del>	<del>99327</del>	<del>142363</del>	<del>.302</del>	<del>586</del>
26	06/01/81	1510	129	124	43819	100111	143930	.304	587
27	06/02/81	0745	130	125	43974	100838	144812	.304	586
28	<del>06/03/81</del>	<del>0730</del>	<del>130</del>	<del>125</del>	<del>45105</del>	<del>101559</del>	<del>146664</del>	<del>.308</del>	<del>590</del>
29	06/04/81	0630	130	124	44386	101586	145972	.304	586
30	06/05/81	0655	130	125.5	45026	100065	145111	.310	593
31	<del>06/06/81</del>	<del>1240</del>	<del>130</del>	<del>125.5</del>	<del>44667</del>	<del>100065</del>	<del>144752</del>	<del>.309</del>	<del>591</del>
32	06/07/81	0830	130	125	44386	100838	145224	.306	588
33	06/08/81	0625	130	125	44386	100838	145224	.306	588
34	<del>06/09/81</del>	<del>0735</del>	<del>131</del>	<del>126.5</del>	<del>43974</del>	<del>102310</del>	<del>146284</del>	<del>.301</del>	<del>584</del>

# Baca 4 Flowtest 3 p. 4 of 5

06/09/81	1230	131	125	43974	102292	146266	.301	584	
06/10/81	0750	132	126	44128	103020	147148	.300	583	
<del>06/11/81</del>	<del>0720</del>	<del>130</del>	<del>124.5</del>	<del>43919</del>	<del>101577</del>	<del>145396</del>	<del>.301</del>	<del>584</del>	
06/12/81	0730	131	125	43666	101190	144976	.302	584	
06/13/81	0900	131	125.5	43396	101199	144595	.300	583	
<del>06/14/81</del>	<del>0700</del>	<del>130</del>	<del>124</del>	<del>43243</del>	<del>100111</del>	<del>143354</del>	<del>.302</del>	<del>584</del>	
06/15/81	0843	131	125	44051	100085	144136	.306	588	
06/16/81	0806	130	124.5	43396	99335	142731	.304	587	
<del>06/17/81</del>	<del>0300</del>	<del>130</del>	<del>125</del>	<del>43819</del>	<del>101944</del>	<del>145763</del>	<del>.301</del>	<del>584</del>	
06/18/81	0830	130	125	43974	100838	144812	.304	586	
06/19/81	0622	130	124.5	43472	100094	143566	.303	586	
<del>06/20/81</del>	<del>1200</del>	<del>130</del>	<del>125</del>	<del>43396</del>	<del>100466</del>	<del>143862</del>	<del>.302</del>	<del>585</del>	
06/21/81	1130	130	125	44128	100085	144213	.306	588	
06/22/81	0757	129	125	42600	101585	145194	.300	583	
<del>06/23/81</del>	<del>0620</del>	<del>130</del>	<del>125</del>	<del>43548</del>	<del>101944</del>	<del>145492</del>	<del>.300</del>	<del>583</del>	
06/24/81	0605	130	125	43548	100076	143624	.303	586	
06/25/81	0625	130	125	43548	100085	143633	.303	586	
<del>06/26/81</del>	<del>0747</del>	<del>130</del>	<del>124.5</del>	<del>43396</del>	<del>101190</del>	<del>144586</del>	<del>.300</del>	<del>583</del>	
06/27/81	1510	130	125	43320	100838	144158	.301	584	
06/28/81	0930	130	126.5	44128	101559	145687	.303	586	
<del>06/29/81</del>	<del>0808</del>	<del>131</del>	<del>126</del>	<del>43548</del>	<del>100449</del>	<del>143997</del>	<del>.302</del>	<del>586</del>	
06/30/81	0530	130	125	43396	100838	144234	.301	584	
07/01/81	0800	155	160	33614	98084	131698	.255	559	
<del>07/01/81</del>	<del>1400</del>	<del>111</del>	<del>105</del>	<del>24625</del>	<del>69694</del>	<del>84589</del>	<del>.260</del>	<del>532</del>	RUPTURE DISC FAILED IN FLOWLINE @ 1130
<del>07/02/81</del>	<del>1000</del>	<del>114</del>	<del>109</del>	<del>25324</del>	<del>62571</del>	<del>87895</del>	<del>.298</del>	<del>565</del>	RUPTURE DISC FAILED IN FLOWLINE @ 1130
<del>07/03/81</del>	<del>0700</del>	<del>114</del>	<del>109</del>	<del>25027</del>	<del>61978</del>	<del>87005</del>	<del>.298</del>	<del>565</del>	RUPTURE DISC FAILED IN FLOWLINE @ 1130
<del>07/04/81</del>	<del>1400</del>	<del>115</del>	<del>109</del>	<del>22193</del>	<del>64263</del>	<del>86556</del>	<del>.250</del>	<del>537</del>	RUPTURE DISC FAILED IN FLOWLINE @ 1130
<del>07/05/81</del>	<del>0630</del>	<del>116</del>	<del>102.5</del>	<del>25226</del>	<del>63162</del>	<del>88409</del>	<del>.295</del>	<del>563</del>	RUPTURE DISC FAILED IN FLOWLINE @ 1130
<del>07/06/81</del>	<del>0610</del>	<del>114</del>	<del>103.5</del>	<del>25226</del>	<del>62583</del>	<del>87809</del>	<del>.287</del>	<del>564</del>	RUPTURE DISC FAILED IN FLOWLINE @ 1130
<del>07/07/81</del>	<del>0745</del>	<del>115</del>	<del>102</del>	<del>25108</del>	<del>62583</del>	<del>88691</del>	<del>.294</del>	<del>570</del>	RUPTURE DISC FAILED IN FLOWLINE @ 1130

# Baca 4 Flowtest 5 of 5

07/08/81	0705	113	108	25176	59509	84685	.297	573	RUPTURE DISC FAILED IN FLOWLINE @ 1130
07/09/81	0715	115	108.5	25226	59498	84724	.298	573	RUPTURE DISC FAILED IN FLOWLINE @ 1130
<del>07/10/81</del>	<del>0814</del>	<del>114</del>	<del>107</del>	<del>25027</del>	<del>59509</del>	<del>84536</del>	<del>.296</del>	<del>571</del>	<del>RUPTURE DISC FAILED IN FLOWLINE @ 1130</del>
07/11/81	0800	115	110	15127	61967	82094	.299	600	RUPTURE DISC FAILED IN FLOWLINE @ 1130
07/12/81	1630	113	107.5	25027	62588	87615	.286	524	RUPTURE DISC FAILED IN FLOWLINE @ 1130
<del>07/13/81</del>	<del>0715</del>	<del>114</del>	<del>108</del>	<del>25210</del>	<del>60122</del>	<del>86232</del>	<del>.304</del>	<del>570</del>	<del>RUPTURE DISC FAILED IN FLOWLINE @ 1130</del>
07/14/81	0910	131	125	41299	107043	148242	.278	564	RUPTURE DISC PLACED ON SEPARATOR @ 0710
07/15/81	0715	131		41661	101993	143654	.290	575	
<del>07/16/81</del>	<del>0705</del>	<del>131</del>		<del>40835</del>	<del>102910</del>	<del>142845</del>	<del>.286</del>	<del>571</del>	
07/17/81	0705	132		41050	98653	139703	.294	578	
07/18/81	0930	132	126	41050	98644	139694	.294	578	
<del>07/19/81</del>	<del>0830</del>	<del>132</del>	<del>127</del>	<del>41050</del>	<del>98635</del>	<del>139655</del>	<del>.294</del>	<del>578</del>	
07/20/81	0730	132	126.5	41121	100506	141627	.290	571	
07/21/81	0721	132	127	41760	100514	142274	.294	578	
<del>07/22/81</del>	<del>0850</del>	<del>131</del>	<del>124</del>	<del>42230</del>	<del>98687</del>	<del>140926</del>	<del>.300</del>	<del>532</del>	<del>SHUTIN WELL @ 1230</del>

To alleviate disposal problem in field.