

Table B. Pumping Test Data, Pumping Well, Coyote Springs Valley, CE-DT-4.

Date (1980)	Time	Depth to Water	Discharge,	Remarks
		below Reference Point feet	gpm	
12/19	0810	352.85		Static water level Pumping Started Step no. 1
	0812	353.45		
	0814	353.53	151	
	0816	353.53		
	0818	353.55		
	0820	353.53	151	
	0825	353.50	151	
	0830	353.61	151	
	0835	353.60		
	0840	353.58	151	
	0845	353.59	151	
	0850	353.59	151	
	0900	353.57	151	
	0910	353.57		
	0920	353.57		Pumping increased
	0922	354.80		Step no. 2
	0924	354.57		
	0925	354.54	365	
	0928	354.54		
	0930	354.53	359	
	0935	354.55	359	
	0940	354.53	359	
	0945	354.52		
	0950	354.50	359	
	0955	354.51		
	1000	354.46	359	
	1010	354.50		
	1020	354.44	354	
	1030	354.43	354	Pumping increased
	1032	357.10		Step no. 3
	1034	357.06		
	1036	357.10		
	1038	357.08		
	1040	357.10	595	
	1045	357.08		
	1050	357.12	595	
	1055	357.08		
	1100	357.16		
	1105	357.07		

Table B. Pumping Test Data, Pumping Well, Coyote Springs Valley, CE-DT-4 (Cont'd)

<u>Date</u>	<u>Time</u>	<u>Depth to Water below Reference Point feet</u>	<u>Discharge, gpm</u>	<u>Remarks</u>
12/19	1110	357.08	595	
	1120	357.15	595	
	1130	357.12	595	
	1140	357.05		Pumping stopped
12/20	0745	352.86		Static water level Pumping started Constant discharge test
	0755	352.85		
	0800	352.85		
	0801	355.88		
	0802	356.13	525	
	0803	356.20		
	0804	356.13	517	
	0805	356.11		
	0806	356.19	525	
	0807	356.10	517	
	0808	356.10		
	0809	356.11		
	0810	356.10		
	0812	356.15	532	
	0814	356.47		
	0816	356.20		
	0818	356.22		
	0820	356.19		
	0825	356.30	540	
	0830	356.30		
	0835	356.26		
	0840	356.16	540	
	0845	356.19		
	0850	356.19	540	
	0855	356.14	540	
	0900	356.22	540	
	0910	356.19	540	
	0920	356.42	540	
	0930	356.21	540	
	0940	356.13	538	
	0950	356.22	538	
	1000	356.21	536	
	1020	356.61	567	

Table B. Pumping Tests Data, Pumping Well, Coyote Springs Valley, CE-DT-4 (Cont'd)

<u>Date</u>	<u>Time</u>	<u>Depth to Water below Reference Point feet</u>	<u>Discharge, gpm</u>	<u>Remarks</u>
12/20	1040	356.23	538	
	1100	356.21	536	
	1130	356.19	536	
	1200	356.18	540	
	1230	356.25	540	
	1300	356.21	540	
	1400	356.20	538	
	1500	356.18	538	
	1600	356.24	540	
	1705	356.19	540	
	1800	356.29	540	
	2000	356.30	540	
	2201	356.39	540	
12/21	0000	356.42	540	
	0200	356.42	540	
	0400	356.36	538	
	0800	356.29	536	
	1200	356.25	538	
	1600	356.32	540	
	2000	356.37	538	
12/22	0000	356.49	540	
	0800	356.32	538	
	1400	356.25	539	
	2002	356.33	538	
12/23	0200	356.46	540	
	0800	356.36	536	
	1300	356.18	539	Pumping stopped
	1301	352.55		Recovery measurements started
	1301.5	352.82		
	1302	352.85		
	1302.5	352.88		
	1303.25	352.88		
	1304	352.87		
	1305	352.86		
	1306	352.90		
	1307	352.87		
	1308	352.86		
	1309	352.83		
	1310	352.83		
	1315	352.83		
	1320	352.83		

Table B. Pumping Tests Data, Pumping Well, Coyote Springs Valley, CE-DT-4 (Cont'd).

<u>Date</u>	<u>Time</u>	<u>Depth to Water below Reference Point, feet</u>	<u>Remarks</u>
12/23	1325	352.83	
	1330	352.87	
	1335	352.81	
	1340	352.80	
	1405	352.87	
	1431	352.80	
	1500	352.80	
	1530	352.83	
	1600	352.81	
	1630	352.81	